


CEILING & FLOOR MOUNTED CONVERTIBLE

koppel

era series
SAVE OZONE
EARTH
R410A SERIES



KPC-36J/3DA
KPC-60J/3DA



**R410A
REFRIGERANT**



**QUIET
DESIGN**



**AUTO
RESTART**



**24HR
TIMER**



**SLEEP
MODE**



**INDEPENDENT
DEHUMIDIFICATION**

Model	Indoor Unit Outdoor Unit	KCM-36R3DA KPC-36J/3DA	KCM-60R3DA KPC-60J/3DA
	TR	3.0	5.0
Cooling Capacity	BTU/Hr	34,800	51,800
	kJ/Hr	36,714	54,649
Power Supply	V/Ph/Hz	230~/60	230/3~/60 +N+G
Rated Power	W	3,950	6,020
Rated Current	A	18.02	18.50
EER	BTU/W-Hr	8.81	8.60
	kJ/W-Hr	9.29	9.08
Star Rating		★	★
Refrigerant		R410A	R410A
Operation Temperature (Min-Max)	°C	17-30	17-30
Applicable Area (Unloaded Space)	SQM	38-63	60-100
Airflow Volume (Hi/Mi/Low)	CMH	1,722/1,459/1,281	2,548/2,104/1,790
Noise Level (Low)	dB(A)	53/49/50	58.7/54.1/49.3
Indoor			
Unit Dimension (WxDxH)	mm	1,285×675×235	1,650×675×235
Packaging Dimension (WxDxH)	mm	1,360×755×318	1,725×755×318
Unit Weight (Net/Gross)	Kg	31.3/37	41.2/47.7
Outdoor			
Unit Dimension (WxDxH)	mm	600×600×759	710×710×843
Packaging Dimension (WxDxH)	mm	628×628×794	738×738×872
Unit Weight (Net/Gross)	Kg	57.8/61.4	78.2/82.8
Piping Connections			
Liquid Pipe Size (Diameter)	mm (in)	Ø9.52 (Ø3/8)	Ø9.52 (Ø3/8)
Gas Pipe Size (Diameter)	mm (in)	Ø19.05 (Ø3/4)	Ø19.05 (Ø3/4)
Max. Refrigerant Pipe Length	m	30	50
Max. Difference in Level	m	20	30

NOTES:

(1) The above data was based on cooling conditions: Indoor air temperature 27°C DB 19°C WB, Outdoor air temperature 35°C DB 24°C WB.

(2) Specifications are subject to change without prior notice for continuous product improvement.

(3) Koppel is a registered trademark of Koppel Inc.

CEBU

CEBU Door 1-2, NSB Bldg.
A, Cortez Avenue, Mandaue City
Tel. No.: (032) 346-7278
Fax No.: (032) 346-7279

ILOILO

Door 8-10, NSB Bldg.,
Rizal Street, Lapuz, Iloilo City
Tel. No.: (033) 330-2926

CAGAYAN DE ORO

CDO 78-78 Warehouse 1,
Zone 5, Cugman
National Highway,
Cagayan de Oro City
Tel. No.: (088) 880-6326

DAVAO

Buhangin Rd. corner Ladislawa Ave.
Davao City
Tel. No.: (082) 308-10403